

Spring 2020

控制系統  
Control Systems

Unit 6J  
PI Compensation and Lag Compensation

Feng-Li Lian & Ming-Li Chiang



NTU-EE

Mar 2020 – Jul 2020

- In many problems,
  - it is important to **keep the bandwidth low**
  - and also to **reduce the steady-state error**
- For this purpose,
  - a **PI Controller**
  - or **Lag Compensator** is useful
- **PI Controller:**

$$D_c(s) = K \left( 1 + \frac{1}{T_I} \frac{1}{s} \right)$$

$$= \frac{K}{s} \left( s + \frac{1}{T_I} \right)$$





$$D_c(s) = \alpha \frac{T_I s + 1}{\alpha T_I s + 1}, \quad \alpha > 1$$

## Low frequency:

- Amplitude: **increase**
- Phase: **decrease**

## Features:

- Provide **additional gain of  $\alpha$**   
in low-frequency range
- Leave the system  
**sufficient PM**
- Put pole/zero  
at **much lower frequency**



1. Determine **OL gain K** that meet the **PM** requirements
2. Draw the **Bode Plot** of the uncompensated system with **crossover frequency** from Step 1, and evaluate the **low-frequency gain**
3. Determine  **$\alpha$**  to meet **low-frequency gain error** requirement
4. Choose the corner frequency  **$\omega = 1/T_I$** , (the zero) to be **one octave to one decade** below new  **$\omega_c$**
5. The other corner frequency  **$\omega = 1/\alpha T_I$** , (the pole)
6. Iterate on the design. Adjust poles/zeros/gain.

## Example 6.18: Lag-Compensation Design for Temperature Control System

$$K G(s) = \frac{K}{\left(\frac{s}{0.5} + 1\right) \left(\frac{s}{1} + 1\right) \left(\frac{s}{2} + 1\right)}$$

- $K_p = 9$

- $PM > 40^\circ$

- (1)



In Ex. 6.16,  $K = 9$

- For  $PM > 40^\circ$ ,

at  $\omega_c \sim < 1$

- $Mag \sim 3$


- $K = 3$



# Examples

## Example 6.18: Lag-Compensation Design for Temperature Control System

- (2)
- $K = 3$
- $PM \approx 50^\circ$
- Low-frequency gain = 3
- (3)
- The low-frequency gain should be raised by a factor of 3,
- $\rightarrow$  the lag compensation needs to have  $\alpha = 3$






# Examples

## Example 6.18: Lag-Compensation Design for Temperature Control System

- (4)
- Zero:  $1 / 5 = 0.2$
- $\rightarrow 1/T_I = 0.2$ , or  $T_I = 5$
- (5)
- $\omega = 1/\alpha T_I = 1/(3 \times 5) = 1/15$

$$D_c(s) = \alpha \frac{5s + 1}{15s + 1}$$

- $K D_I(0)G(0) = 3K = 9$
- $K_p = 9$ ,  $PM = 44^\circ$



## Example 6.19: Lag Compensation for the DC Motor

$$G(s) = \frac{1}{s(s+1)}$$

▪  $K = 10$

▪  $PM = 20^\circ$  at  $\omega_c \approx 3$

▪ Select break points

✓  $\omega_c$  is lowered

✓ more favorable PM results


➤ Lag zero = 0.10

➤ Lag pole = 0.01

✓  $PM = 50^\circ$

▪ Error constant:  $K_v = 10$

▪  $PM = 45^\circ$






- Example 6.19: Lag Compensation for the DC Motor

$$G(s) = \frac{1}{s(s+1)}$$

- Error constant:  $K_v = 10$

- PM =  $45^\circ$



- No steady-state error
  - ✓ a Type 1 system
- Settling time  $\approx 25$  sec
- Rise time  $\approx 2$  sec

- Example 6.15: Lead Compensation

